

Flame Detection

TALENTUM® FLAME DETECTOR IR3 [EN] 16589-00, [FM] 16589-20

The Talentum® Flame Detector IR3 is designed to protect areas where open fires may be expected and detects almost all flames, including hydrocarbon fires with 4.3 μm emissions through to invisible fires such as hydrogen.

The Flame Detector is sensitive to flickering, low frequency $(I-I5\ Hz)$ infra-red radiation emitted by flames during combustion even if the lens is contaminated by a layer of oil, dust, water, vapour or ice.

This detector has three IR sensors which respond to different IR wavelengths in order to discriminate between flames and spurious sources of radiation. False alarms from flickering sunlight are avoided by a combination of filters and signal processing techniques.

The Flame Detector IR3 has selectable output options of relay contacts or 4-20 mA signal, as standard.



FEATURES
Excellent immunity to false sources
Tolerant of fumes, vapours, dust and mist
Suitable for indoor and outdoor areas
Unaffected by convection currents, draughts or wind
Proven response to multiple fuel types
Multi-spectrum detection
Selectable output options
Selectable response speed
Selectable sensitivity levels
Built in auto and manual test
Low current consumption
Fast response to fire

APPROVALS

Worldwide approvals include EN54-10 certification. Visit **ffeuk.com** for up to date approvals information.

APPLICATIONS	
Agriculture	Military and marine
Aircraft hangars	Nuclear power sites
Automotive	Pharmaceutical production
Biomass storage and handling	Printing
Coal handling and milling	Spray booths
Compressor stations	Storage tanks
Dust collection	Textile processing
Engine rooms	Tunnels
Fuel loading racks	Waste recycling
High voltage applications	Woodworking

ACCESSORIE	·s
07127-00	Adjustable Mounting Bracket
12545-00	Weather Shield [SS]
1800-101	Talentum Test Torch
12556-00	Air Purge Adapter







TALENTUM® **FLAME DETECTOR IR3** [EN] 16589-00, [FM] 16589-20

Wiring

MECHANICAL SPECIFICATION Die cast zinc alloy (ZAI2) Housing material Blue RAL 240 50 35 Housing colour $142(h) \times 108(w) \times 79(d) mm$ Dimensions $5 \text{ I/2"(h)} \times 4 \text{ I/4"(w)} \times 3 \text{ I/8"(d)}$ Weight 1.75 kg (3.8 lbs) Cable gland entries 2 x 20 mm (13/16")

I.0 to 4.0 mm² (I2-I8 AWG)

ELECTRICAL SPECIFICATION			
Supply voltage	I4 to 30 Vdc		
Quiescent current	8 mA, RL2 energised 4 mA, current loop, RL2 off 3 mA, RL2 off		
Alarm current	28 mA, RLI & RL2 energised 20 mA, current loop, RLI & 2 off 9 mA, RLI energised		
Power-up time	2 seconds max.		
Test signal voltage	I4 to 30 Vdc		
Relay outputs	Programmable operation including latching or non-latching		
Relay maximum ratings			
Current	0.75 A		
Voltage	48 VDC		
Power	30 W		
(Note: resistive loads only)			

ENVIRONMENTAL	
Operating temperature	-10°C to $+55$ °C (14 °F to 131 °F)
Storage temperature	-20°C to $+65$ °C (-4 °F to 149 °F)
Relative humidity	95% non condensing
IP rating	IP65

Refer to User Manual for further details

PERFORMANCE		
Range		
High (Class I)*	0.1 m ² n-Heptane at 25 m	
Low (Class 3)	0.1 m ² n-Heptane at 12 m	
	(see EN54-10 for sensitivity settings)	
Field of view	90° min. Cone	
Operating wavelength		
IR	I.0 to 2.7 μm	
* Has been tested and approved at Class I		

FFE Limited t +44 (0) 1462 444
9 Hunting Gate, Hitchin
Hertfordshire SG4 0T w ffeuk.com


t +44 (0) I462 444 740

Flame Detection

RESPONSE CH	ARACTERIST	ICS – HIGH S	ENSITIVITY
Fuel	Flame size m² (in²)	Distance m (ft)	Approval
n-Heptane*	0. l	25	EN54-10
(Yellow flame)	(144)	(82)	
Methylated spirit*	0.25	25	EN54-10
(Clear flame)	(400)	(82)	
n-Heptane	0. l	25	FM
(Yellow flame)	(144)	(82)	
Methylated spirit	0.25	25	FM
(Clear flame)	(400)	(82)	
JP Jet Fuel	0. l	25	FM
(Yellow flame)	(144)	(82)	


^{*} Has been tested and approved at Class I

FIELD OF VIEW



To meet the requirements of EN54-10:2002 clause 5.4 (Directional Dependence), viewing angles must not exceed ±30°.

DIMENSIONS



INSTALLATION RECOMMENDATIONS

Please refer to our User Manual for mounting and wiring instructions. The installation of Talentum® flame detectors should be undertaken in accordance with recognised national or international standards and codes of practice.

Specifications and wiring information are provided for information only and are believed to be accurate. FFE Ltd assumes no responsibility for their use. Data and design are subject to change without notice. Installation and wiring instructions are shipped with the products and should always be used for actual installation. For more information, contact your Sales Representative. Document Part No: 24-0244-07